

CERTIFICATE FI 29760

Our Ref. 280272-3

Product PVC power cable with concentric conductor

Type MCMK

Trade mark TF KABLE 3 or 5

**Certificate Holder/
Manufacturer** TELE-FONIKA KABLE S.A.
UL. Hipolita Cegielskiego 1
PL 32-400 MYSLENICE
POLAND

Technical information Number and nominal cross-sectional area of conductors:
1x1,5+1,5 - 10+10 mm²
2x1,5+1,5 - 10+10 mm²
3x1,5+1,5 - 300+150 mm²
3x35+16+16 - 300+150+150 mm²
4x1,5+1,5 - 300+150 mm²

Other information Rated voltage 0,6/1 kV

The product is certified according to the following standard(s) HD 603 S1:1994 + A1:1997 + A2:2003 + A3:2007 Part 3 Section F
SFS 4880:2008

Validity This certificate is valid until 25 November 2021 provided that the Conditions for FI certification are met. This certificate includes the right to use the FI mark under the condition that product changes (if any) will be approved at SGS Fimko before the product is brought onto market.

Directive information The certified product(s) fulfils requirements of above mentioned standard(s) which are harmonised under the Low Voltage Directive (2014/35/EU) at the date of issue of the certificate.

Date of issue 25 November 2016

SGS Fimko Ltd

Signature

Sixten Lökfors
Project Manager

This certificate has 1 appendix



This certificate is issued by the company under its General Conditions for Certification Services accessible at <http://www.sgs.fi/en/Terms-and-Conditions.aspx>. Attention is drawn to the limitations of liability defined therein and in the Test Report here above mentioned which findings are reflected in this certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Appendix to Certificate: 29760

Manufacturing sites

TELE-FONIKA KABLE S.A. (TF KABLE 3)
 ul. Wielicka 114
 PL 30-663 KRAKOW
 POLAND

TELE-FONIKA KABLE S.A. (TF KABLE 5)
 ul. Fordonska 152
 PL 85-957 BYDGOSZCZ
 POLAND

Additional Information

This certificate replaces Certificate FI 27863 A3 dated 30 December 2015, due to changed name of Certificate holder and Manufacturer and to new testing.

